


## Connection between MS3790 and ML311



Terminal n° 5 is used only to allow the right RTD's wiring (connected in series)

To connect 2 wire probe:  
 T1: connect the probe to terminal block 2 and 3, bridge on 1-2 and 3-5  
 T2: connect the probe to terminal block 6 and 7, bridge on 5-6 and 7-8